

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

LISTING No. 7320-1173:102 Page 1 of 1

CATEGORY: Speakers

LISTEE: Atlas/Soundolier, 1859 Intertech Dr., Fenton MO 63026  
Contact: \*Bruce Marlin (972) 875-8413 Fax (972) 875-8416

DESIGN: Models UAT25C, UAT25C-A, UAT25C-B, UAT70C, UAT70C-A, UAT70C-B, UATM-25C, UATM-25C-A, UATM-25C-B, UATM70C, UATM70C-A, UATM70C-B, UA-4, UH, UH-T25, UH-T25-C, UH-T70, UH-T70- C, UK, UK-T25, UK-T25-1, UK-T25-2, UK-T70-1, UK-T70-2, SUHT-70C, SUHT-25C, UDT-25C, UDT-25CB, UDT-70C, UDT-70CB, UST82C and UST87C speakers. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as speakers for use with separately listed compatible fire alarm control units. If these appliances are required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliances must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7320-0771:001

\*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 24, 2005**

*Listing Expires June 30, 2006*

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager